



File EX2487 Vol 1 Issued 12/30/1966
Revised 05/30/2002

FOLLOW-UP SERVICE PROCEDURE
(TYPE R)

VALVES, TRIM AND DRAIN
(VQGU, VQGU7)

Manufacturer: UNITED BRASS WORKS INC
(728811-001) 714 S MAIN ST
RANDLEMAN NC 27317

Applicant: SAME AS MANUFACTURER
(728811-001)

Listee: SAME AS MANUFACTURER
(728811-001)

This Procedure authorizes the above Manufacturer to use the marking specified by Underwriters Laboratories Inc. only on products covered by this Procedure, in accordance with the applicable Follow-Up Service Agreement.

The prescribed Mark or Marking shall be used only at the above manufacturing location on such products which comply with this Procedure and any other applicable requirements.

The Procedure contains information for the use of the above named Manufacturer and representatives of Underwriters Laboratories Inc. and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it is not to be copied, either wholly or in part, and that it will be returned to Underwriters Laboratories Inc. upon request.

This PROCEDURE, and any subsequent revisions, is the property of UNDERWRITERS LABORATORIES INC. and is not transferable.

UNDERWRITERS LABORATORIES INC.

A handwritten signature in cursive script, appearing to read 'A.W. Schaefer'.

A.W. Schaefer
Vice President and General Manager
Laboratory Management and Operations

N


(FILE IMMEDIATELY AFTER AUTHORIZATION PAGE)

L I S T I N G M A R K

PROCUREMENT:

All Listing Marks shall be obtained from a supplier authorized by Underwriters Laboratories Inc. unless the Listing Mark is molded, cast, die-stamped, rubber stamped, silk screened or reproduced by the manufacturer-himself.

COMPOSITION AND ELEMENTS:





1. UL in circle symbol:
2. The word "LISTED".
3. The assigned control number(s): 167H
4. Product identity. Consists of the following:



"TRIM VALVE", "DRAIN VALVE", or "TRIM AND DRAIN VALVE" or other appropriate product names as indicated in the individual Procedure section(s).

APPLICATION - ON PRODUCT:

For use on Listed products only - Not to be used on Recognized Components.

Where the device is physically too small for all four elements of the Listing Mark Composition, the following is acceptable, sand cast or stamped on the product.

 or  , LISTED* (Control Number**)

* Exception: Where the manufacturer demonstrates the available space on the product does not even provide space on which to either cast or stamp "LISTED" in association with the  or  , the follow-up Procedure may specify the products and sizes on which "LISTED" may be omitted.

** Where these devices are serially numbered at the factory, the serial number may be the control number provided the manufacturer keeps a log by serial number of the model number, size, and date shipped from the plant; the log would become a portion of the UL Representative's report of inspection and be sent to Northbrook for file.

APPLICATION - ON PACKAGING:

Where packaging is provided, the complete four element Listing Mark Composition shall appear on the smallest unit package if the complete four element Listing Mark does not appear on the product. This may be in the form of a separable Listing Mark.

THIS PAGE IS TO BE REVISED BY FUS DEPARTMENT ONLY

DESCRIPTION

PRODUCT COVERED:

*

USL, CNL - Trim and drain valves for the sizes and working pressure shown below:

<u>Model</u>	<u>Type</u>	<u>Size, in.</u>	<u>Rated Pressure, psig, (kPa)</u>
125SUL	Globe	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	250 (1720)
126SUL	Angle	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	250 (1720)

MARKING:

Each valve shall be marked with the following:

- A. Name or identifying symbol of the manufacturer "UNITED" or Private labeler.
- B. Nominal size of valve (cast on body).
- C. Distinctive model designation.
- D. Rated working pressure (cast on body).
- E. An arrow on the valve handle or handwheel, clearly and legibly Showing the direction to turn the handle for the "Open" and/or "Closed" positions.
- F. Date of manufacture by year (may be abbreviated or in an Established or other traceable code).

Each valve shall bear the appropriate nameplate as shown on the Parts List for each valve.

In addition to the above markings, each valve shall bear the UL Listing Mark described on the Listing Mark Data Page at the front of this Procedure.